

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130430-S789  
**Report Reference** S789-20101001  
**Issue Date** 2012-APRIL-30

**Issued to:** HONEYWELL SECURITY  
SUITE 100  
2 CORPORATE CENTER DR  
PO BOX 9040  
MELVILLE NY 11747

**This is to certify that  
representative samples of**

CONTROL UNIT ACCESSORIES, SYSTEM; CENTRAL  
STATION ALARM UNITS; LOCAL ALARM UNITS;  
POLICE-STATION-CONNECTED ALARM UNITS;  
PROPRIETARY ALARM UNITS

Fire Alarm Equipment: Internet and Digital Cellular Fire  
Communicator:


Models iPGSM-COM, iPGSM-DP, iPGSM-4G

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL864, Control Units and Accessories for Fire Alarm  
Systems


**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested  
according to the current UL requirements.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

